

# SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number<sup>1</sup>:

MMC-003-R2

## Issuer details

Name<sup>2</sup> (of New Zealand manufacturer or importer):

MM Cables NZ Ltd

Telephone: +64 9 412 2432

New Zealand Company No. (if applicable): 4387825

Email Address: info@mmcables.nz

Contact Address:

1A Tapu Rd  
Huapai  
Kumeu 0810  
New Zealand

## Article – Details<sup>3</sup> (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

Low Voltage Copper PVC Neutral Screen Power Cables 0.6/1kV (refer to Appendix A for additional details)  
Low Voltage Copper XLPE Neutral Screen Power Cables 0.6/1kV (refer to Appendix A for additional details)  
Low Voltage Aluminium XLPE Neutral Screen Power Cables 0.6/1kV (refer to Appendix A for additional details)

## The Article listed above, fully complies:

### With cited standard(s), as listed<sup>4</sup>:

Standard number and issue year: AS/NZS 4961:2003

Edition / Amendment status:

Standard title:

Electric cables - Polymeric insulated - For distribution and service applications

Standard number and issue year:

Edition / Amendment status:

Standard title:

AS/NZS ZZ modified Yes  No  N/A

AS/NZS ZZ modified Yes  No  N/A

OR Complies with the Conformity Cooperation Agreement<sup>5</sup> Yes  No

## Names and addresses of any testing organisation or body

Name(s): SIRIM QAS International Sdn Bhd

Address(es): No. 1, Persiaran Dato' Menteri  
40700 Shah Alam,  
Selangor Darul Ehsan, Malaysia

Name(s):

Address(es):

## Reference to relevant test reports/certification and the issue date that show how compliance is achieved

Standard(s) or document(s) used, to show how compliance with cited standard is achieved:

AS/NZS 4961:2003

Report Certification or Document reference N°(s):

2017EEA01025  
2017EEA01026

Issue dates(s):

14/11/2017  
14/11/2017

Reference to any management quality system involved: ISO 9001:2015

Additional information<sup>6</sup>: Manufacturers Quality Management System Certificate No. QMS 00330

## Declaration (signed for and on behalf of)

Name and position as authorized by the issuer<sup>7</sup>:

Jason Sewell, Engineering & Technical Manager

Issuer Identification (as affixed to the article):

MM Cables

Signature:



Date:

12/4/2019

# SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

## Appendix 1 – Product Details

### 1) Low Voltage Copper PVC Neutral Screen Power Cables 0.6/1kV

AS/NZS 4961

1C, 2C, 3C, 4C

2.5mm<sup>2</sup> - 16mm<sup>2</sup>

Stranded Copper Conductor

V-90 Insulation, V-90 Sheath

Copper Wire Screen

Coloured cores

Circular configuration

0.6/1kV rated voltage

### 2) Low Voltage Copper XLPE Neutral Screen Power Cables 0.6/1kV

AS/NZS 4961

1C, 2C, 3C, 4C

25mm<sup>2</sup> – 95mm<sup>2</sup>

Stranded Copper Conductor

X-90 Insulation, V-90 Sheath

Copper Wire Screen

Coloured cores

Circular configuration

0.6/1kV rated voltage

### 3) Low Voltage Aluminium XLPE Neutral Screen Power Cables 0.6/1kV

AS/NZS 4961

1C, 3C, 3C+P

35mm<sup>2</sup> – 300mm<sup>2</sup>

Stranded Aluminium Conductor

X-90 Insulation, V-90 Sheath

Copper Wire Screen

Coloured cores

Circular configuration

0.6/1kV rated voltage