

SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number¹: MMC-006-R1

Issuer details

Name² (of New Zealand manufacturer or importer):

MM Cables NZ Ltd

Telephone: +64 9 412 2432

New Zealand Company No. (if applicable): 4387825

Email Address: info@mmcables.nz

Contact Address:

1A Tapu Rd
Huapai
Kumeu 0810
New Zealand

Medium Risk Article – Details³ (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

Low Voltage PVC Power Cables 450/750V (refer to Appendix A for additional details)

The Medium Risk Article listed above, fully complies:

With cited standard(s), as listed⁴:

Standard number and issue year: AS/NZS 5000.2:2006

Edition / Amendment status:

Standard title:

Electric cables - Polymeric insulated - For working voltages up to and including 450/750 V

Standard number and issue year:

Edition / Amendment status:

Standard title:

AS/NZS ZZ modified Yes No N/A

AS/NZS ZZ modified Yes No N/A

OR Complies with the Conformity Cooperation Agreement⁵ Yes No

Names and addresses of any testing organisation or body

Name(s): SIRIM QAS International Sdn Bhd

Address(es): No. 1, Persiaran Dato' Menteri
40700 Shah Alam,
Selangor Darul Ehsan, Malaysia

Name(s):

Address(es):

Reference to relevant test reports/certification and the issue date that show how compliance is achieved

Standard(s) or document(s) used, to show how compliance with cited standard is achieved:

AS/NZS 5000.2:2006

Report Certification or Document reference N°(s):

2017EEA01021

Issue dates(s):

14/11/2017

Reference to any management quality system involved: ISO 9001:2008

Additional information⁶: Manufacturers Quality Management System Certificate No. 0772

Declaration (signed for and on behalf of)

Name and position as authorized by the issuer⁷:

Jason Sewell, Engineering & Technical Manager

Issuer Identification (as affixed to the article):

MM Cables

Signature:



Date:

1/02/2018

SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

Appendix 1 - Product Details

1) Low Voltage PVC Power Cables 450/750V

AS/NZS 5000.2

2C, 2C+E, 3C, 3C+E, 4C, 4C+E

1.5mm² to 6mm²

Stranded Copper Conductor

V-90 Insulation, 5V-90 Sheath

Coloured cores

Circular configuration

450/750V rated voltage