

# SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number<sup>1</sup>: MMC-001-R2

## Issuer details

Name<sup>2</sup> (of New Zealand manufacturer or importer):

PHEL Cable t/a MM Cables NZ

Telephone: 0508 222 536

New Zealand Company No. (if applicable): 9250915

Email Address: bruce@mmcables.nz

Contact Address:

289 Rosebank road  
Avondale 1026  
Auckland

## Medium Risk Article – Details<sup>3</sup> (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

Low Voltage PVC Control Cables 450/750V (refer to Appendix A for additional details)  
Low Voltage PVC SWA Control Cables 450/750V (refer to Appendix A for additional details)

## The Medium Risk Article listed above, fully complies:

### With cited standard(s), as listed<sup>4</sup>:

Standard number and issue year: A5000.3:2003

Edition / Amendment status:

Standard title:

Electric cables—Polymeric insulated Part 3: Multicore control cables

Standard number and issue year:

Edition / Amendment status:

Standard title:

AS/NZS ZZ modified Yes  No  N/A

AS/NZS ZZ modified Yes  No  N/A

OR Complies with the Conformity Cooperation Agreement<sup>5</sup> Yes  No

## Names and addresses of any testing organisation or body

Name(s): SIRM QAS International Sdn Bhd

Address(es): No. 1, Persiaran Dato' Menteri  
40700 Shah Alam,  
Selangor Darul Ehsan, Malaysia

Name(s):

Address(es):

## Reference to relevant test reports/certification and the issue date that show how compliance is achieved

Standard(s) or document(s) used, to show how compliance with cited standard is achieved:

A5000.3:2003

Report Certification or Document reference N°(s):

2017EEA01022

Issue dates(s):

14/11/2017

Reference to any management quality system involved: ISO 9001 : 2008

Additional information<sup>6</sup>: Registration number 0772

## Declaration (signed for and on behalf of)

Name and position as authorized by the issuer<sup>7</sup>:

Bruce Morton, Procurement Manager

Issuer Identification (as affixed to the article):

PHEL Cables t/a MM Cables

Signature:



Date:

15/11/2024

# SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

## Appendix 1 – Product Details

### 1) Low Voltage PVC Control Cables 450/750V

AS/NZS 5000.3

7C to 37C

1.5mm<sup>2</sup> to 2.5mm<sup>2</sup>

Stranded Copper Conductor

V-90 Insulation, 5V-90 Sheath

Numbered cores

Circular configuration

450/750V rated voltage

### 2) Low Voltage PVC SWA Control Cables 450/750V

AS/NZS 5000.3

7C to 37C

1.5mm<sup>2</sup> to 2.5mm<sup>2</sup>

Stranded Copper Conductor

V-90 Insulation, 5V-90 Sheath

Numbered cores

Circular configuration

Steel wire armoured

450/750V rated voltage