

SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number¹: MMC-003-R3

Issuer details

Name² (of New Zealand manufacturer or importer):

PHEL Cables t/a MM Cables NZ

Telephone: 0508 222 537

New Zealand Company No. (if applicable): 9250915

Email Address: info@mmcables.nz

Contact Address:

289 Rosebank Road
Avondale
Auckland
New Zealand

Article – Details³ (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

Low Voltage Copper PVC Neutral Screen Power Cables 0.6/1kV (refer to Appendix A for additional details)
Low Voltage Copper XLPE Neutral Screen Power Cables 0.6/1kV (refer to Appendix A for additional details)
Low Voltage Aluminium XLPE Neutral Screen Power Cables 0.6/1kV (refer to Appendix A for additional details)

The Article listed above, fully complies:

With cited standard(s), as listed⁴:

Standard number and issue year: AS/NZS 4961:2003

Edition / Amendment status:

Standard title:

Electric cables - Polymeric insulated - For distribution and service applications

Standard number and issue year:

Edition / Amendment status:

Standard title:

AS/NZS ZZ modified Yes No N/A

AS/NZS ZZ modified Yes No N/A

OR Complies with the Conformity Cooperation Agreement⁵ Yes No

Names and addresses of any testing organisation or body

Name(s): SIRIM QAS International Sdn Bhd

Address(es): No. 1, Persiaran Dato' Menteri
40700 Shah Alam,
Selangor Darul Ehsan, Malaysia

Name(s):

Address(es):

Reference to relevant test reports/certification and the issue date that show how compliance is achieved

Standard(s) or document(s) used, to show how compliance with cited standard is achieved:

AS/NZS 4961:2003

Report Certification or Document reference N°(s):

2017EEA01025
2017EEA01026

Issue dates(s):

14/11/2017
14/11/2017

Reference to any management quality system involved: ISO 9001:2015

Additional information⁶: Manufacturers Quality Management System Certificate No. QMS 00330

Declaration (signed for and on behalf of)

Name and position as authorized by the issuer⁷:

Jason Sewell, Engineering & Technical Manager

Issuer Identification (as affixed to the article):

MM Cables

Signature:



Date:

12/4/2019

SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

Appendix 1 – Product Details

1) Low Voltage Copper PVC Neutral Screen Power Cables 0.6/1kV

AS/NZS 4961

1C, 2C, 3C, 4C

2.5mm² - 16mm²

Stranded Copper Conductor

V-90 Insulation, V-90 Sheath

Copper Wire Screen

Coloured cores

Circular configuration

0.6/1kV rated voltage

2) Low Voltage Copper XLPE Neutral Screen Power Cables 0.6/1kV

AS/NZS 4961

1C, 2C, 3C, 4C

25mm² – 95mm²

Stranded Copper Conductor

X-90 Insulation, V-90 Sheath

Copper Wire Screen

Coloured cores

Circular configuration

0.6/1kV rated voltage

3) Low Voltage Aluminium XLPE Neutral Screen Power Cables 0.6/1kV

AS/NZS 4961

1C, 3C, 3C+P

35mm² – 300mm²

Stranded Aluminium Conductor

X-90 Insulation, V-90 Sheath

Copper Wire Screen

Coloured cores

Circular configuration

0.6/1kV rated voltage